




120-277 or 347VAC Recessed Linear Light Fixture



WARNING! Luminaire must be installed by a qualified electrician. Refer to local codes for proper installation. To prevent shock disconnect power before installation on service.









Required Opening Size


| Fixture | Dimension | Required Opening | Weight |
|------------------------|---------------|------------------|--------|
| 2ft Y23 | 2" x 3" x 24" | 2¼" x 3¼" x 24¼" | 5 Lbs |
| 4ft Y23 | 2" x 3" x 46" | 2¼" × 3¼" × 46¼" | 7 Lbs |
| 6ft Y23 | 2" × 3" × 68" | 2¼" x 3¼" x 68¼" | 9 Lbs |
| 8ft Y23 | 2" x 3" x 90" | 2¼" x 3¼" x 90¼" | 12 Lbs |
| 2ft Y33 | 3" x 3" x 24" | 3¼" x 3¼" x 24¼" | 6 Lbs |
| 4ft Y33 | 3" x 3" x 46" | 3¼" x 3¼" x 46¼" | 9 Lbs |
| 6ft Y <mark>33</mark> | 3" x 3" x 68" | 3¼" x 3¼" x 68¼" | 12 Lbs |
| 8 <mark>ft Y3</mark> 3 | 3" x 3" x 90" | 3¼" x 3¼" x 90¼" | 14 Lbs |
| 2ft Y43 | 4" × 3" × 24" | 4¼" x 3¼" x 24¼" | 7 Lbs |
| 4ft Y43 | 4" x 3" x 46" | 4¼" x 3¼" x 46¼" | 10 Lbs |
| 6ft Y4 <mark>3</mark> | 4" x 3" x 68" | 4¼" x 3¼" x 68¼" | 14 Lbs |
| 8ft Y43 | 4" x 3" x 90" | 4¼" × 3¼" × 90¼" | 17 Lbs |

Direct Screw Installation





Trimless Installation



Drop-Ceiling Installation




GlowbackLED® 1173 NW 159th Ave Miami Gardens, FL 33169 1-800-679-4902 • info@bluegateinc.com





120-277 or 347VAC Recessed Linear Light Fixture

Direct Screw Installation



Reccomended Installation Method!


Framing Required! Build framing on sides and top of light fixture for support.


Create Opening: Refer to chart on Page 1 for re-


quired opening size.


Type IC: Suitable for IC contact.


Inherently Protected
















120-277 or 347VAC Recessed Linear Light Fixture

Twist-Clip Installation




Twist Clip Mounting: Specialized clip secures light fixture to drywall.


Create Opening: Refer to chart on Page 1 for re-


quired opening size.


Type IC: Suitable for IC contact.


Inherently Protected














ure will grip onto drywall.

GlowbackLED® 1173 NW 159th Ave Miami Gardens, FL 33169 1-800-679-4902 • info@bluegateinc.com





120-277 or 347VAC Recessed Linear Light Fixture

Drop Ceiling Installation





Adjustable Grid-Bracket: Adaptable to any grid structure and configuration.


T-Grid Set Screw Opening: Refer to chart on **Page 1** for required opening size. Opening created using grid-structure. **Suspension:** Grid system must be suspended from ceiling and able to support weights listed on **Page 1**.


Type IC: Suitable for IC contact.

Inherently Protected














120-277 or 347VAC Recessed Linear Light Fixture

Twist-Clip Installation



Framing Required! Build framing on either side of light fixture.


Create Opening: Refer to chart on **Page 1** for required opening size.


Screw Spacing: Mounting screws are required every


16" on center. #6 Screw Reccomended


Type IC: Suitable for IC contact.

Inherently Protected










Prepare Light Fixture for Plaster Work: Apply single layer of contractor's tape to channel opening (if lens removed), or lens. Do not use multiple layers of tape. If covering channel opening, make sure to cover area where lens snaps into place.

Plaster Preparation: Apply single layer of drywall tape over plaster bead to avoid cracking.

Plaster Notes: For areas experiencing regular vibration (by doors) use **Durabond** to void cracking.

DO NOT USE "Soft-Mud" (Pre-Mixed Joint Compound)



Use compound knife for a smooth finish. Sand, paint, and finish all drywall work before removing contractor's tape.

Make electrical connections (See page 6)


GlowbackLED® 1173 NW 159th Ave Miami Gardens, FL 33169 1-800-679-4902 • info@bluegateinc.com







120-277 or 347VAC Recessed Linear Light Fixture


Linkable/Continous Run Connections






Inner Clip Connection






vas built. Make sure light fixture sits flat d grid brackets go over grid structure




Drop light fixture down into the opening that was created when ceiling structure was built. Make sure light fixture sits flat, and grid brackets go over grid structu



Before inserting inner-channel be sure to make electrical connections using the provided connectors. Connection should be secure.

Make sure that every clip is engaged and resting in its locked position.




GlowbackLED® 1173 NW 159th Ave Miami Gardens, FL 33169 1-800-679-4902 • info@bluegateinc.com







120-277 or 347VAC Recessed Linear Light Fixture

Power-Feed Entry and Electrical Connections






Non-Dimmable Configuration



Dimmable Configuration



GlowbackLED® 1173 NW 159th Ave Miami Gardens, FL 33169 1-800-679-4902 • info@bluegateinc.com

